NVWA Rapport

Het Waterlaboratorium

J.W. Lucasweg 2
2031 BE Haarlem

Postbus 734
2003 RS Haarlem
t 023-517 59 00
e info@hetwaterlaboratorium.nl

Company: **Dunea**
Location: **Scheveningen**
Name: **Drinking water**
Measurement data: **1st quarter 2026**

Parameter	Unit	minimum	average	maximum	norm DWB minimum	norm DWB maximum
Aluminium	µg/l	3.3	3.3	3.3		200
Arsenic	µg/l	1.79	1.98	2.18		10
Boron	mg/l	0.044	0.044	0.044		0,5
Calcium	mg/l	38.08	47.76	77.80		
Chloride	mg/l	57	60	64		150**
Carbon Dioxide	mg/l	0.6	0.9	1.5		
Carbonate	mg/l	< 5	7	12		
Copper	µg/l	< 0.5	< 0.5	< 0.5		
Conductivity at 20°C	mS/m	52.7	53.7	55.4		<125
Fluoride	mg/l	0.13	0.14	0.15		1
Iron	mg/l	< 0.005	< 0.005	< 0.005		0,2
Turbidity	FTE	< 0.03	< 0.03	0.06		1
Odour (qualitative)		absent	absent	absent		****
Bicarbonate	mg/l	172	176	182	>60	
Mercury	µg/l	< 0.01	< 0.01	< 0.01		1
Total hardness	mmol/l	1.25	1.55	2.32	>1	
Total hardness	°D	7,0	8,7	13	>5.6	
Colour	mg/l Pt	4	4	5		20
Magnesium	mg/l	7.27	8.59	9.39		
Manganese	mg/l	< 0.005	< 0.005	< 0.005		0,05
Sodium	mg/l	62.5	62.5	62.5		150
Ammonium	mg/l NH4	< 0.05	< 0.05	< 0.05		0,2
Nitrite	mg/l NO2	< 0.007	< 0.007	< 0.007		0,1
Nitrate	mg/l NO3	5.34	6.5	7.15		50
Oxygen, dissolved	mg/l	9.2	9.5	9.9	>2	
Lead	µg/l	< 0.2	< 0.2	< 0.2		5
Hydrogen ion concentration	pH	7.99	8.55	8.76	7	9,5
Orthophosphate	mg/l PO4	0.21	0.21	0.21		
Selenium	µg/l	< 0.5	< 0.5	< 0.5		10
Saturation index, calculated	pH	0.59	0.79	0.95	> -0.2	
Taste (qualitative)		absent	absent	absent		****
Sulphate	mg/l	41.1	42.9	43.9		150
Temperature	°C	11	11.7	12.6		25
Total Organic Carbon	mg/l	1.52	1.66	1.72		****
Aeromonas	kve/100 ml	0	1	1		1000
Coliform bacteria 37°C	kve/100 ml	0	0	0		0
Escherichia coliform	kve/100 ml	0	0	0		0
Clostridium perfringens	kve/100 ml	0	0	0		0
Enterococcus	kve/100 ml	0	0	0		0
Colony count (22 °C)	kve/ml	0	1	1		100***
Legionella	kve/l	<100	<100	<100		<100

** norm annual average *** geometric norm annual average **** no abnormal change