

Company: Dunea
Location: Scheveningen
Name: Drinking water
Measurement data: 4th quarter 2025

J.W. Lucasweg 2
 2031 BE Haarlem

Postbus 734
 2003 RS Haarlem
 t 023-517 59 00
 e info@hetwaterlaboratorium.nl

Parameter	Unit	minimum	average	maximum	norm DWB minimum	norm DWB maximum
Aluminium	µg/l	5,5	5,5	5,5		200
Arsenic	µg/l	2,28	2,34	2,39		10
Boron	mg/l	0,046	0,046	0,046		0,5
Calcium	mg/l	39,38	43,91	46,92		
Chloride	mg/l	54	56	58		150**
Carbon Dioxide	mg/l	0,7	0,8	0,9		
Carbonate	mg/l	6	7	9		
Copper	µg/l	< 0,5	< 0,5	< 0,5		
Conductivity at 20°C	mS/m	51,1	52,1	53,0		<125
Fluoride	mg/l	0,16	0,17	0,17		1
Iron	mg/l	< 0,005	< 0,005	< 0,005		0,2
Turbidity	FTE	< 0,03	< 0,03	< 0,03		1
Odour (qualitative)		absent	absent	absent		****
Bicarbonate	mg/l	168	170	172	>60	
Mercury	µg/l	< 0,01	< 0,01	< 0,01		1
Total hardness	mmol/l	1,31	1,44	1,53	>1	
Total hardness	°D	7,3	8,1	8,6	>5.6	
Colour	mg/l Pt	2	3	3		20
Magnesium	mg/l	7,63	8,31	9,12		
Manganese	mg/l	< 0,005	< 0,005	< 0,005		0,05
Sodium	mg/l	53,6	53,6	53,6		150
Ammonium	mg/l NH4	< 0,05	< 0,05	< 0,05		0,2
Nitrite	mg/l NO2	< 0,007	< 0,007	< 0,007		0,1
Nitrate	mg/l NO3	2,84	2,95	3,05		50
Oxygen, dissolved	mg/l	9,0	9,1	9,2	>2	
Lead	µg/l	< 0,2	< 0,2	< 0,2		5
Hydrogen ion concentration	pH	8,37	8,54	8,66	7	9,5
Orthophosphate	mg/l PO4	0,17	0,17	0,17		
Selenium	µg/l	< 0,5	< 0,5	< 0,5		10
Saturation index, calculated	pH	0,73	0,78	0,82	> -0.2	
Taste (qualitative)		absent	absent	absent		****
Sulphate	mg/l	45	45,7	46,4		150
Temperature	°C	13	14,3	15,3		25
Total Organic Carbon	mg/l	1,22	1,22	1,22		****
Aeromonas	kve/100 ml	0	1	1		1000
Coliform bacteria 37°C	kve/100 ml	0	0	0		0
Escherichia coliform	kve/100 ml	0	0	0		0
Clostridium perfringens	kve/100 ml	0	0	0		0
Enterococcus	kve/100 ml	0	0	0		0
Colony count (22 °C)	kve/ml	0	1	2		100***
Legionella	kve/l	<100	<100	<100		<100

** norm annual average *** geometric norm annual average **** no abnormal change